

Certification Report

Report No.: CR-1:70288

CUSTOMER INFORMATION

Name: Brentwood Industries
Address: Tomas Alva Edison Park, Boulevard Corredor Tijuana-Rosarito 2000 # 15202 Int MT-3C, Zona Cerril General
City: Tijuana
State: B.C.
ZIP: 22330

EQUIPMENT INFORMATION

ID Number: CR-1
Manufacturer: N/A
Model: N/A
Description: Clean Room
Serial Number: N/A

This is to certify, that the test results recorded in the attached test report are correct, accurate and were conducted in accordance with the requirements of the applicable standards mentioned in this document. Therefore, only covers the tests in the test report. With the issuance of this certificate, Test Solutions de México, S.A. de C.V. accepts full responsibility for the accuracy of the test results and certification. This certification expires on the due date indicated. All the equipment used is traceable to a national laboratory as the National Institute of Standards and Technology (NIST) and/or the Centro Nacional de Metrología (CENAM).

This Certification Report complies with the requirements of ISO/IEC 17025:2017, and shall not be reproduced, except in full, without the written permission of the Laboratory issuing this report.

TEST INFORMATION

Area Status: "Operational"
Test Interval: Yearly
Test Date: 18-Mar-2020
Due Date: 18-Mar-2021
Temperature: 19.9 °C
Humidity: 53.0 %RH
Tech Comments: Attached Data Sheet(s).

Class: ISO-7
Type: Non-Unidirectional
Performed by: Carlos Ramirez
Procedure Used: ISO 14644-1 & 3

This Clean Room complies with the standards; **ISO 14644-1:2015, ISO 14644-3:2019 & IEST-RP-CC006.3.**

Production Room - ISO Class 7 at 0.5, 1.0 & 5.0 µm, Raw Materials Room - ISO Class 7 at 0.5, 1.0 & 5.0 µm and Gowning Room - ISO Class 7 at 0.5 µm & 1.0 µm.

EQUIPMENT USED

Asset #	Description	Cal. Date	Due Date	Traceability #
172	Fluke 975 AirMeter	10/9/2019	10/9/2020	2927036
220	TSI Alnor EBT731 Balometer	4/12/2019	4/12/2020	EBT73131644014
238	Air Techniques International 2i Digital Aerosol Photometer	10/24/2019	10/24/2020	30344
246	Met One 3413 Particle Counter	6/27/2019	6/27/2020	1804525035



Q.A. Representative: Daniel Perez Reyes